



May 26, 2026

Upper Merrimack River Local Advisory Committee
PO Box 3019
Penacook, NH 03303

RE: UMLAC Transmittal – Amoskeag Beverages
Tax Map 88, Block Z, Lots 3 & 4
510 Hall Street
Bow, NH 03304
GE Project No. 26-0218-5

Dear Chair Tremblay,

In response to the Committee's review letter dated May 18, 2026, we are resubmitting a revised AoT Amendment package addressing the comments on the original submittal. A response to those comments is outlined below:

1. The UMLAC noted that there are no page numbers included with the Section 5. PROJECT NARRATIVE portion of the application package and that complicated the review by individual UMLAC members and hindered the group review at our monthly meeting.

Section 5: PROJECT NARRATIVE has been updated to include references to specific plans/exhibits from Section 9. Additional, a plan number has been added to the top left corner of each sheet in Section 9 to make it easier to identify plans.

2. The UMLAC questions whether the proposed seeds or seed mixes mentioned in the application package will be coated with neonicotinoids. If so, are there other sources of seed mix that would lack that coating and be more appropriate within the designated river corridor?

A specification has been added to the Grading Plan (Sheet 6 of 12 / Page B7 of Section 9) for grass matching the recommendations from the original approved AoT Permit #2464. The plan calls for installation of Pearl's Premium Grass which is organic and does not contain neonicotinoids.

3. Not all pages received in hard copy plan set are found in the PDF. UMLAC reviewers could not refer to pages referenced in the narrative since those pages were not found within the PDF.

Section 9 has been updated to include the entire Site Plan set for the proposed improvements covered by this amendment.

4. The UMLAC noted that "CLF" does not appear in the legend. This would be helpful during review for those familiar with this particular acronym.

The note regarding relocation of "CLF" has been revised to use "chain link fence" on the Removals Plan (Sheet 4 of 12 / Page B5 of Section 9). The legend includes linetypes for "chain link fence" and "items to be removed" that match the plan view.

We trust these responses and plan revisions will satisfactorily address the Committee's comments.. Should you have any questions or require further information, please do not hesitate to contact me directly.

Best Regards,



Jonathan Christie
Project Manager